

To: Brown, Jamesr[brown.jamesr@epa.gov]
From: Phillips, Pam
Sent: Fri 8/7/2015 11:59:40 PM
Subject: RE: Gold King Mine-pH readings from operators

Thanks

Sent from my Windows Phone

From: Brown, Jamesr
Sent: 8/7/2015 6:53 PM
To: Phillips, Pam; Garcia, David
Subject: FW: Gold King Mine-pH readings from operators

Contact info at the end of these messages.

Sent from my Windows Phone

From: Restivo, Angela
Sent: 8/7/2015 4:36 PM
To: Brown, Jamesr; Garcia, David; McCasland, Mark; Kirkland, Robert; McCoy, Melinda; Foster, Althea; Crossland, Ronnie; Webster, Susan; Rauscher, Jon; Turner, Philip
Subject: Gold King Mine-pH readings from operators

FYI one update correction on pH at Northstar

From: Romero, Nora, NMENV [mailto:Nora.Romero2@state.nm.us]
Sent: Friday, August 07, 2015 4:17 PM
To: Restivo, Angela
Subject: RE: Gold King Mine-pH readings from operators

Clarification from Nathan Yarbrow at Northstar, the pH is 8.7 and at this time the plume hasn't reached the intake site.

From: Romero, Nora, NMENV
Sent: Friday, August 07, 2015 12:10 PM
To: 'Restivo, Angela'
Subject: RE: Gold King Mine-pH readings from operators

Hello Angela,

As per your request

		Date: August 6 or 7, 2015	
Water System No.	Water System Name	pH	Turbidity
NM3509824	Aztec Domestic Water System	8.12	18 NTU
NM3510224	Farmington Water System	7.67	4.35 NTU
NM3510524	Morningstar Water Supply System	7.9	28 NTU
NM3520024	Northstar MDWCA		no reading - intake valve has been closed since July 29.
		8.7	

From: Restivo, Angela [<mailto:Restivo.Angela@epa.gov>]
Sent: Friday, August 07, 2015 8:34 AM
To: Romero, Nora, NMENV
Subject: RE: Gold King Mine-pH readings from operators

Thank you.

From: Romero, Nora, NMENV [<mailto:Nora.Romero2@state.nm.us>]
Sent: Friday, August 07, 2015 9:31 AM
To: Restivo, Angela
Cc: Garcia, David; Brown, Jamesr; Kirkland, Robert; McCasland, Mark; Foster, Althea; Crossland, Ronnie; Skibitski, Thomas, NMENV
Subject: RE: Gold King Mine-pH readings from operators

Angela

I will work on that

From: Restivo, Angela [<mailto:Restivo.Angela@epa.gov>]

Sent: Friday, August 07, 2015 8:29 AM

To: Romero, Nora, NMENV

Cc: Garcia, David; Brown, James; Kirkland, Robert; McCasland, Mark; Foster, Althea; Crossland, Ronnie; Skibitski, Thomas, NMENV

Subject: Gold King Mine-pH readings from operators

Nora,

Can you get the pH levels from each of the systems on the river? This information would be helpful in our flow and water quality calculations.

Thanks.

Angela Restivo

Compliance Officer

Drinking Water Section

U.S. EPA Region 6

1445 Ross Ave (6WQ-SD)

Dallas, Texas 75202-2733

phone: 214-665-7123